

Philadelphia



Water Department

## Memorandum

**To:** Joan Decker, Records Commissioner  
**From:** Howard Neukrug, Water Commissioner  
**Date:** 1/22/2015  
**Re:** **Amendments to the Philadelphia Water Department Regulations – Regulation Section 404.0**

---

Please find attached for filing amendments to the Philadelphia Water Department (“PWD”) Regulations. In accordance with Section 8-407 of the City Charter, I am filing these Amendments with your Department in order to initiate the public inspection period. Also, please find attached a memorandum from the Law Department approving these Amendments.

Thank you for your assistance in this matter.

A handwritten signature in black ink, appearing to read 'Howard Neukrug', written over a horizontal line.

Howard Neukrug  
Water Commissioner

cc: Debra A. McCarty, Deputy Water Commissioner, Operations  
Mary Josephine Markle, Assistant City Solicitor

884271

DEPARTMENT OF RECORDS  
2015 FEB -3 PM 4: 31



**City of Philadelphia**

**LAW DEPARTMENT  
Water Division  
1101 Market Street  
5<sup>th</sup> Floor  
Philadelphia, PA 19107**

**MEMORANDUM**

**TO: Howard M. Neukrug, Commissioner  
Debra A. McCarty, Deputy Commissioner  
Philadelphia Water Department**

**FROM: Mary Josephine Markle, Assistant City Solicitor  
Water Division**

**DATE: January 22, 2015**


**SUBJECT: AMENDMENT TO PHILADELPHIA WATER DEPARTMENT  
REGULATIONS**

884272

---

I have reviewed the attached Amendment to Section 404.0 of the Philadelphia Water Department Regulations and find the regulation to be legal and in proper form.

In accordance with Section 8-407(a) of The Philadelphia Home Rule Charter, you may forward this Regulation to the Department of Records where they will be made available for public inspection.

  
Mary Josephine Markle  
Assistant City Solicitor

DEPARTMENT OF RECORDS  
2015 FEB -3 PM 4:31

**Proposed Amendment to Current Regulation**

PWD Regulations

Chapter 4: Water

404.0 Residential Fire Sprinkler Systems (RFSS)

...

*(c) Metering*

*(1) A Department-approved Underwriters Laboratories (UL) listed RFSS meter shall be installed on the water supply line. In a Branch System, the meter shall be installed upstream of any branching of the domestic water line and sprinkler system line.*

884273

---

**Proposed Final Regulation**

PWD Regulations

Chapter 4: Water

404.0 Residential Fire Sprinkler Systems (RFSS)

...

*(c) Metering*

*(1) A Department-approved RFSS meter shall be installed on the water supply line. In a Branch System, the meter shall be installed upstream of any branching of the domestic water line and sprinkler system line.*

DEPARTMENT OF RECORDS  
2015 FEB -3 PM 3:01